



ENGINEERING SUCCESS

CERTIFICATE OF CONFORMANCE

29 October 2015

Customer: LANDE ENDÜSTRİYEL METAL ÜRÜN. SAN. VE TİC. A.Ş.
Purchase Order #: 5686
NTS Opportunity #: OP0177627

Equipment Identification

Name of Equipment: Lande Dynacentre / Dynamax Range Cabinets
Equipment Model Number: LN-SRDC 428010-CC consist of LN-SR 42U8010-CC Frame Module
Equipment Type: Datacenter rack
Equipment Description: Lande Seismic Datacenter Cabinet with doors
Supplier/Manufacturer: LANDE ENDÜSTRİYEL METAL ÜRÜN. SAN. VE TİC. A.Ş

National Technical Systems (NTS) certifies that the above referenced item has been tested in accordance with the requirements of **Telcordia Technologies GR-63-CORE Issue 4, Section 4.4 Earthquake Environment Criteria and Verizon VZ.TPR.9305 Section 7.7 Earthquake Requirements**. The product complied with all applicable requirements and objectives for frame level equipment in a **Zone 4** seismic environment.

Please refer to the ITL TCG report **K2T1000x** for details on the testing and compliance.

If there are any specific questions regarding the NEBS compliance of the above referenced product please feel free to contact the NTS program manager directly.



Deniz Ezgi
NTS Program Manager
Tel: +49 89 787475 160